

بسم الله الرحمن الرحيم

DATE: 23-Dec-14 التاريخ  
PERMIT # PS-167242-PA رقم الطلب



وزارة الداخلية  
الإدارة العامة للدفاع المدني  
إدارة الوقاية

TECHNICAL REPORT

التقرير الفني لمعدات الإطفاء والسلامة

PRODUCT:	EXTERIOR WALL CONSTRUCTIONS (CLASS NUMBER 4881)	المنتج:
PRODUCT APPLICATION:	PASSIVE FIRE PROTECTION COMPONENT	تصنيف المعدة:
APPLICANT / P.O. BOX	FTC QATAR	مقدم الطلب/صندوق البريد:
MANUFACTURER / LOCATION:	IZOPOLI YAPI ELEMANLARI TAAH SAN VE TIC AS / TURKEY	الشركة المصنعة:
PRODUCT/MODEL	<p>Exterior Wall Constructions (Class Number 4881)</p> <p>Product: "KS103SSF", "KS103MSF" Wall Panel</p> <p>FM Approved exterior wall systems are Class 1 fire rated in accordance with Approval Standard 4880. Class 1 exterior wall systems may be rated for use to unlimited height, a maximum height of 50 ft (15.2 m) or a maximum height of 30 ft (9.1 m). as listed in FM Approval</p> <p>Note: The listed assemblies are not intended as long-term fire walls or barriers since fire endurance was not evaluated. See SPECIFICATION TESTED PRODUCTS, ASTM E119 Standard, for hourly rated systems.</p> <p>This product cannot be considered as a component of a composite material to attain the specified fire rating.</p>	قائمة المنتجات:
3RD PARTY CERTIFICATE / APPROVAL	FM APPROVED	شهادات المختبرات المساندة(من هيئات معتمدة):

RECOMMENDATIONS

التوصيات

The QCDD has reviewed the submission of the above mentioned applicant and finds NO OBJECTION to the sale and use of the Fire Safety Product/ Equipment herein stated, whose authenticity was supported by applicant's submission of its 3rd Party test/approval certifications. The authority of this approval extends up to the installation of this product which shall be performed only by competent person/technician duly certified by QCDD.

The product shall bear the mark of the certifying body and shall be verified by the engineer prior to installation. This product approval is valid up to two (2) year from the date of issue.

MANUFACTURER'S NAME/LOGO/FM APPROVED

ENGINEERS

المهندسين OFFICERS

الضابط المختص

--	--

بسم الله الرحمن الرحيم

التاريخ: 23/12/2014  
الموافق: 02/03/1436  
رقم الطلب: 167242



وزارة الداخلية  
الإدارة العامة للدفاع المدني  
إدارة الوقاية

شهادة الإدارة العامة للدفاع المدني

23023100020001

شهادة عدم ممتعة استيراد معدات و أجهزة و مواد نظم  
الوقاية و مكافحة الحريق

نوع الشهادة

رقم الشهادة

2014/12/23

التاريخ

37846

رقم رخصة البناء

اسم المرخص له اشرف عبدالرحيم محمد ابو عيسى وشركاه

0

اسم المالك

38190

رقم السجل التجاري

اف تي سي - قطر

الاسم التجاري

1

رقم الوحدة

44466111

هاتف المكتب

55516682

الهاتف الجوال

44466112

رقم الفاكس

صندوق البريد

ashraf@bluesalon.com

البريد الالكتروني

اسم  
محمود بن حمد

للشارع:

231

رقم الشارع:

23

رقم المنطقة:

رقم المبنى:

2

رقم قطعة  
الأرض:

تفاصيل الشهادة

تمت الموافقة على المنتج ( EXTERIOR WALL CONSTRUCTIONS (CLASS NUMBER 4881 ) وذلك حسب التقرير الفني الصادر بتاريخ 23/12/2014 والمرفق طيه صورته منه

ملاحظة :-

( يرجى الإطلاع على الإشرطات في خلف الشهادة والإلتزام بها )



توقيع مدير إدارة الوقاية:

الإدارة العامة للدفاع المدني

تاريخ انتهاء الشهادة 2016/12/24

تاريخ إصدار الشهادة 2014/12/25

توقيع الضابط المختص:  
إدارة الوقاية